


## DG M WE 600 (952 302)


- Prewired complete unit consisting of a base part and plug-in protection modules
- High discharge capacity due to heavy-duty zinc oxide varistors/spark gaps
- High reliability due to "Thermo Dynamic Control" SPD monitoring device



Figure without obligation



Basic circuit diagram DG M WE 600 FM



Dimension drawing DG M WE 600 FM

Three-pole modular surge arrester for use in wind turbines with a rated varistor voltage  $U_{mov} = 750 \text{ V a.c.}$ ; FM version with floating remote signalling contact

Type Part No.	DG M WE 600 952 302
SPD according to EN 61643-11	Type 2
SPD according to IEC 61643-1/-11	Class II
Nominal a.c. voltage ( $U_N$ )	600 V
Max. continuous operating a.c. voltage ( $U_C$ )	600 V
Rated varistor voltage ( $U_{mov}$ )	750 V
Nominal discharge current (8/20 $\mu\text{s}$ ) ( $I_n$ )	15 kA
Max. discharge current (8/20 $\mu\text{s}$ ) ( $I_{max}$ )	25 kA
Voltage protection level ( $U_P$ )	$\leq 3 \text{ kV}$
Voltage protection level at 5 kA ( $U_P$ )	$\leq 2.5 \text{ kV}$
Response time ( $t_A$ )	$\leq 25 \text{ ns}$
Max. mains-side overcurrent protection	100 A gL/gG
Short-circuit withstand capability for max. mains-side overcurrent protection	25 kA <sub>rms</sub>
Temporary overvoltage (TOV) ( $U_T$ )	900 V / 5 sec.
TOV characteristic	withstand
Operating temperature range ( $T_U$ )	-40°C...+80°C
Operating state/fault indication	green / red
Number of ports	1
Cross-sectional area (min.)	1.5 mm <sup>2</sup> solid/flexible
Cross-sectional area (max.)	35 mm <sup>2</sup> stranded/25 mm <sup>2</sup> flexible
For mounting on	35 mm DIN rails acc. to EN 60715
Enclosure material	thermoplastic, red, UL 94 V-0
Place of installation	indoor installation
Degree of protection	IP 20
Capacity	3 module(s), DIN 43880
Approvals	KEMA, UL, VdS
Weight	386 g
Customs tariff number	85363030
GTIN	4013364113305
PU	1 pc(s)

We reserve the right to introduce changes in performance, configuration and technology, dimensions, weights and materials in the course of technical progress. The figures are shown without obligation.